



CLOPAY MODELS H400, H401 (24 GA. EXTERIOR SKIN)

CLOPAY MODELS H300, H301, H310 (27 GA. MIN. EXTERIOR SKIN)

OPTIONAL WINDOW LITES AVAILABLE IN ALL MODELS. (SEE SECTION B-B)

REVISIONS



REV. NO.	ZONE:	DATE:	ECN NO.	APPVD:	DESCRIPTION
00	-	4/25/03	ER1022	SH	ORIGINAL ISSUE






THIS DOOR MEETS OR EXCEEDS THE DESIGN LOADS FOR THE WIND SPEEDS LISTED BELOW ACCORDING TO THE 2000 INTERNATIONAL BUILDING/RESID. CODE FOR THE FOLLOWING CONDITIONS: 1) ENCLOSED BUILDING, 2) DOOR HAS 2' OF WIDTH IN BUILDING'S END ZONE, 3) IMPORTANCE FACTOR OF 1.0, 4) ANY ROOF SLOPE, AND 5) 50% SAFETY FACTOR.

WIND SPEED (MPH)	≤ 90
EXPOSURE LEVEL	B
MEAN ROOF HEIGHT	30'

DOOR HEIGHT	# OF SECTIONS
8'-3" TO 8'-9"	5
9'-0" TO 10'-0"	6



DOOR HEIGHT "L"	"L"
8'-6"	94"
9'-0"	100"
9'-6"	106"
10'-0"	112"
10'-6"	118"
11'-0"	124"
11'-6"	130"
12'-0"	136"



NOTE: THE DESIGN OF THE SUPPORTING STRUCTURAL ELEMENTS SHALL BE THE RESPONSIBILITY OF THE PROFESSIONAL OF RECORD FOR THE BUILDING OR STRUCTURE AND IN ACCORDANCE WITH CURRENT BUILDING CODES FOR THE LOADS LISTED ON THIS DRAWING.

NOTICE: Confidential/Proprietary information of CLOPAY BUILDING PRODUCTS CO. is contained herein and may not be disclosed, used, duplicated, made available, or distributed without its prior consent. Failure to observe this notice may result in liability for any damages and losses resulting therefrom.

Third Angle Projection

Unless Stated Otherwise TOLERANCES are

.0	± .03
.00	± .015
.000	± .005
.0000	± .001
Degrees	± 1/2°

Unless Stated Otherwise DIMENSIONS ARE IN INCHES.

Glopay 8585 Duke Boulevard
Mason, OH 45040
Tel. No. 1-513-381-4800
Building Products Company Fax No. 1-513-762-3519

DESIGN ENGINEER: MARK WESTERFIELD, P.E.
FLORIDA P.E. #48495, NC P.E. #23832, TEXAS P.E. #91513

DESIGN LOADS: +12.5, -14.0 PSF
TEST LOADS: +19.0, -21.0 PSF

DESCRIPTION: H400/H401/H310/H300/H301 18' +12.5/-14.0 PSF DES.

DRAWN BY: DAS DATE: 11/22/02 SCALE: NTS DWG. B

CHECKED BY: DATE: SHEET 1 OF 1 SIZE B

DWG. NO.: 102760 REV. NO. 00